



GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



SEE RULE - 18(2)

F O R M - (G)

No: F&ES/FPW/

29(XVI) | 3826 | 22

Dated Guwahati the

18/4/22

To,

The Principal,
For Kendriya Vidyalaya,
North Lakhimpur,
Dist:- Lakhimpur, Assam.

RENEWAL OF NO OBJECTION CERTIFICATE IN RESPECT OF INBUILT FIRE FIGHTING/
FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN **THE KENDRIYA VIDYALAYA**
LOCATED AT NORTH LAKHIMPUR, DIST:- LAKHIMPUR, ASSAM.

With reference to your completion report under No. Nil Dated 24.03.2022
and on the basis of the Inspection Report submitted by Sr. Station Officer, Ram Prasad Doley, I hereby
certify that the building as per description below at Dag No. **508, 509** Patta No. **Govt. Land** Mouza
Nakari, (Place- **North Lakhimpur, Lakhimpur**) has been inspected in respect of implementation of
inbuilt Fire Fighting/ Fire Prevention/ Escape means measures and is declared fit in respect of fire
safety. The Fire & Emergency Services, Assam has No Objection in its occupation /utilization for the
purpose of **SCHOOL** subject to conditions mentioned over leaf.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR:-

1. Floor area:- 204 ft²
2. Purpose of utilization:-
For School Purpose.

FIRST FLOOR:-

1. Floor area:- 204 ft²
2. Purpose of utilization:-
For School Purpose.

SECOND FLOOR:-

1. Floor area:- 204 ft²
2. Purpose of utilization:-
For School Purpose.

Details of inbuilt Fire Fighting and Fire Prevention measures:

1. Hose Reel Hose system
2. Down Comer system
3. Manually Operated Electric Fire Alarm system
4. Fire Extinguishers- 13 Nos.
5. Water Reservoir
6. Terrace Water Tank
7. Fire Pump

S.P. cum F&ES Adviser
for and on behalf of
Director of Fire and Emergency Services, Assam,
Guwahati.

NO. F&ES/FPW/

Copy to:-

1. The Deputy Commissioner, **Lakhimpur**, Assam for information.
2. The Superintendent of Police, **Lakhimpur**, Assam for information.
3. The Chairman, **North Lakhimpur Municipal Board**, Assam for information.
4. The Sr. Station Officer, **North Lakhimpur F&ES Station**, for information and necessary action.

Dated Guwahati the

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

(((2)))

CONDITIONS:-

1. The N.O.C. is valid up to: - **31.03.2023**
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically.
There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time.
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/
projection.
7. **The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.**

Nayud
S.P. cum F&ES Adviser
for and on behalf of
Director of Fire & Emergency Services, Assam.
Assam
Ambaraj Guwahati